CALIBRATION CERTIFICATE

CAL20261112EX01

Example Wharf

CERTIFICATE

Certificate number	CAL20261112EX01
Test date	12 November 2026
Engineer	Alex Example
Next due	12 November 2027

CUSTOMER

Head office	Example Kitchens Ltd
Address	1 Example Street London E1 1AA
Site	Example Wharf
Customer reference	EXAMPLE REF 44021

REFERENCE INSTRUMENT

MAKE	MODEL	SERIAL NUMBER	CALIBRATION DATE
Testo	110	EX000000	12 November 2025

RESULTS

UNIT	SETPOINT	INTERNAL	CONTROLLER	PROBE	PROBE DIFFERENCE	SETPOINT DIFFERENCE	CUSTOMER RANGE	RESULT
Walk in fridge Fridge, asset EXFR01, product Milk	3.0°C	3.4°C	3.2°C	3.6°C	0.4°C	0.4°C	0.0°C to 5.0°C	Pass
Prep counter Fridge, asset EXFR02	4.0°C	6.0°C	2.0°C	4.0°C	2.0°C	2.0°C	*Not recorded*	Pass
Freezer room Freezer, asset EXFZ01, product Ice cream	−18.0°C	−18.5°C	−18.0°C	−19.0°C	1.0°C	0.5°C	−22.0°C to −18.0°C	Pass
Display fridge Display fridge, asset EXDF01, product Yoghurt	3.0°C	3.5°C	3.0°C	4.0°C	1.0°C	0.5°C	0.0°C to 4.0°C	Pass

Overall result: Pass

Tolerances used: probe and setpoint within 2.0°C, internal within customer range where given.

SIGN OFF

CUSTOMER



Jordan Example

ENGINEER



Alex Example